

SPECIFICATIONS:
 TYPE: J120X-5355
 RANGE: 2 TO 20 psi
 (137.9 to 1379.0 mbar)
 E/R: 15 AMP 125/250 VAC
 WETTED MATERIAL: BRASS
 SET POINT: 6 psi ±2 ON RISE
 DIFFERENTIAL: 3±2 psi
 UL LISTED
 LISTED IND CONT EQ914
 ASSEMBLE & CALIBRATE PER
 MF'G. PROC. P-94


TYPE: J120X-5835
 RANGE: 10 TO 130 psi
 (0.7 to 9.0 bar)
 E/R: 15 AMP 125/250 VAC
 WETTED MATERIAL: BRASS
 SET POINT: 40 psi ±5 ON RISE
 DIFFERENTIAL: 3±2 psi
 UL LISTED
 LISTED IND CONT EQ914
 ASSEMBLE & CALIBRATE PER
 MF'G. PROC. P-94

| | | | | |
|-----------|---|---------|-----|------|
| J | REDRAWN, UPDATED ENCLOSURE & COVER. ECN#E1553 | 1-26-06 | SR | LK |
| SYM | DESCRIPTION | DATE | DWN | APPD |
| REVISIONS | | | | |

| | |
|---|--------------|
| ORIGINAL DATE | 11-20-91 |
| DRWN | P. WEILER |
| CHKD | P. WEILER |
| APPD | A. MINASSIAN |
| UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES | |
| TOLERANCES ON FRACTIONS ±1/64 | |
| 2 PLACE DEC 3 PLACE DEC ANGLES ±0.010 ±0.005 ±1/2° | |
| DO NOT SCALE THIS DRAWING | |

| | |
|-------|-----------------------------|
| TITLE | J120X-5355 & 5835 SPRINKLER |
| SCALE | 1:2 |

DF001D



UNITED ELECTRIC CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS

DWG NO
 A-12834