

UL LISTED, cUL CERTIFIED.
 CLASS I DIVISION 2, GROUPS A, B, C, D.
 CLASS II DIVISION 2, GROUP F, G.
 CLASS III. ENCLOSURE TYPE 4X
 CLASS I, ZONE 2, GROUP IIC T6

RANGE: 30" Hg Vac TO 0 psi
 -1.0 TO 0 bar

I & M SHEET IMP117.


COVER REMOVED IN FRONT VIEW

U	CHANGED kPa TO bar. ECN#E0047	10-23-02	S.R.	H.N.
T	REVISED VIEW OF TERMINAL BLOCK & SPECS. ECN#C8438	11-22-99	S.R.	VPD
S	CERTIFICATION WAS CSA. REQUIREMENT NOTE WAS NEMA 4X, 7, 9. ECN#C7775	12-3-98	P.V.	S.F.
R	ADDED 1" (25.4mm) & 5/16 (7.94mm) DIMENSIONS. ECN#C6848	10-31-97	P.V.	A.M.
P	CLASS III WAS NEMA 4, 4X, 9, IP65. DELETED ISSEP, GROUPS E & F. REVISED ENCLOSURE & COVER ON "M" DW'G ECN#C5183	1-16-96	P.V.	J.S.M.
N	REVISED TO CAPTIVE COVER SCREW. ECN#C5019	11-30-95	P.W.	J.S.M.
M	REDRAWN & UPDATED PER ECN#C2571	10-1-93	P.W.	A.M.
SYM	DESCRIPTION	DATE	DVN	APPD
REVISIONS				

ORIGINAL DATE	6-16-87
DRWN	A. EBALD
CHKD	A.J. FLECCA
APPD	L. KHATCHADOURIAN
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	

TITLE	H117-218
SCALE	HALF

DF001D



UNITED ELECTRIC
 CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS

DWG NO
A-12765

DO NOT SCALE THIS DRAWING