


DF001D

UE

DVG NO A-12920


UNITED ELECTRIC CONTROLS COMPANY VATERTOWN * MASSACHUSETTS



TERMINALS: #1 COMMON

#2 NORMALLY CLOSED

#3 NORMALLY OPEN



MODEL	ADJUSTABLE RANGE						
N□.	psi	bar					
10-F10	4 T□ 50	0.3 T□ 3.4					
10-F11	10 T□ 150	0.7 T□ 10.3					
10-F12	30 T□ 600	2.1 TO 41.0					

SPECIFICATIONS:
UL RECOGNIZED, CSA CERTIFIED
E/R: 5 AMPS 250 VAC

					DRIGINAL DATE 5-28-92	TITLE		
					™ PETER WEILER	10-F		
Н	CHANGED kPa TO bar. ECN#E0044	10-23-02	Z.R.	H.N.	O-KD PETER WEILER	SERIES		
G	REVISED RANGES PER ECN#C5565	5-10-96	P.V.	LK.	APPD L. KHATCHADORIAN	(DIAPHRAGM)		
_	REDRAWN. DELETED (VIOLET) FROM COMMON: (BLACK) FROM NORMALLY CLOSED; & (BLUE) FROM NORM, OPEN. ECN‡C5459	4-11-96	P.W.	L.K.	UNLESS OTHERVISE SPECIFIED DIMENSIONS ARE IN INCHES	(DITTINGED)		
MYZ	DESCRIPTION	DATE	DVN	APPD				
REVISIONS					III NOT SCALE THIS DRAVING	SCALE FULL		