


CERTIFICATE OF SEISMIC COMPLIANCE

For AQ-, AQP- and AL-Type A-Series Lighting Panels

Qualified to IEEE-693-2005

Qualified to IBC-2006

$S_{ds} = 1.3g$, $S_s = 200\%$, $I_p = 1.5$, for $z/h > 0$
 $S_{ds} = 2.0g$, $S_s = 300\%$, $I_p = 1.5$, for $z/h = 0$
in accordance with ICC-ES-AC156.



Lowest equipment natural frequency: 7 Hz Qualified by shake-table testing, Wyle Laboratories, Dec. 2005

THIS IS TO CERTIFY THAT THE ABOVE NAMED EQUIPMENT MEETS OR EXCEEDS ALL OF THE ABOVE REQUIREMENTS ACCORDING TO IEEE-693-2005 AND IBC-2006.

Certification Report Prepared by

W. E. Gundy & Associates, Inc.
P.O.Box 2900, Hailey, ID, 83333

See GE document 10095950P1 for Certification Report, interpretation of test data and P.E. stamp.

